CIVIL-TECH CONSULTANTS AND ENGINEERS

Building & Highway Material Testing Laboratory

NABL - Accredited Laboratory as per ISO / IEC-17025 :2005

T-2377

Job No.: CTCE/BBMP/W.No.07/KA/CSR-01/735/CUBE/2014-15 23.01.2015

TEST REPORT ON COMPRESSIVE STRENGTH OF CONCRETE CUBES

*** Customer** : **Asst. Executive Engineer,** Kodigehalli Sub Division, BBMP, Bangalore.

*** Agency** : **Mr. K. Amruthraj,** Contractor, Bangalore.

*** Name of the work** : Providing of Name Boars in Kempapura and Pampa Extension surrounding in Ward No. 07, Byatarayanapura, BBMP, Bangalore.

*** Reference** : AEE/KH/211/2014-15 Dated: 14.01.2015

*** Sample ID** : Pavement Concrete

Size of cubes : 150mmx150mmx150mm

Cross Sectional Area : 22500 mm^2

Technical Reference : IS: 516-1959 (Reaffirmed 2008)

*** Grade of Concrete** : M_{20}

Compressive Strength as on : 7^{th} day

Sample Received on : 22.01.2015

Sl.No.	* Date of casting	Date of testing	Weight of cube (Kg)	Failure load (KN)	Compressive strength (N/mm^2)
1	16.01.2015	23.01.2015	8.086	353.6	15.72
2	16.01.2015	23.01.2015	8.124	365.4	16.24
3	16.01.2015	23.01.2015	8.217	381.7	16.96

* Information is furnished by the Customer/Representative

Note:

1. The report shall not be reproduced, except in full, without the written approval of the laboratory.
2. The results indicated above are based on the tests carried out on the samples received in the laboratory.
3. Any Query regarding the report must be reported within 30 days from the date of testing.

****

Civil-Tech Consultants & Engineers Bangalore

VISHWANATH .C
Quality Manager

AE-7

#23/14, 7th Cross, 3rd Stage, 4th Block, Shakthi Ganapathi Nagara, Basaveshwaranagar, Bangalore-79.
Tele Fax : 23223227, Website : www.civiltechconsultants.com
E-mail : vishwanath.ia@civiltechconsultants.com / info@civiltechconsultants.com